DEPARTMENT OF ENVIRONMENT,
HEALTH, & NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH

SHEET 1 OF 1
PROPERTY I.D.#: 2H3C2
PROPERTY RECORDED: YES
COUNTY: Iredell

SOIL/SITE EVALUATION
FOR
ON-SITE WASTEWATER SYSTEM

APPLICANT: Herman McGee OWNER: ✓ AGENT: PHONE:
ADDRESS: Rt 11, Box 746 Mooresville, NC APPLICATION DATE: 7/13/93 DATE EVALUATED: 7/13/93
PROPOSED FACILITY: 3 bedroom SF Dwelling
PROPERTY SIZE: ~ 200'x200'
LOCATION OF SITE: 115 S. / TR 1102 on left common Lot w/ Mt Ulla Loop
WATER SUPPLY: On-Site Well ✓ Comm. Well ___ Public ___ Other ___ EVAL. METHOD: Auger Boring ✓ Pit ___ Cut ___

PROFILE #	.1940 LANDSCP POS. (%)	HORIZON DEPTH (IN.)	.1941 STRUCTURE/TEXTURE	.1941 MINERALOGY/ CONSISTENCE	.1942 WETNESS COND.	.1944 RESTRICT HORIZONS	.1948 CLASS OF HORIZ	1943/ 1956 SAPRLT CLASS.	HORIZON LTAR
1	SS	0-2"	gr / sbk	M / fi-vfr	—	—	PS	—	.5
		2-36"	sbk / c	1:1 / fi	—	—	PS	—	.35-.4
		36-48"	sbk / c-cL	1:1 / fi	—	—	PS	—	.35
2									
3									
4									
5									

AVAILABLE SPACE (.1948): PS SITE CLASSIFICATION (.1948): PS SITE LONG-TERM ACCEPTANCE RATE: .35
EVALUATED BY: [signature] OTHER(S) PRESENT:
COMMENTS: