4646-04-4589

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Eddins Const. Co. H.J. Wallace owner DATE March 6, '79 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION 1100 T.L. on 1179 T.L. on 3rd rd.

S. R. No. _____

SUBDIVISION NAME Crystal Bay LOT NO. 48 SECTION OR BLOCK NO. _____

House (✓) Mobile Home ( ) Business ( ) Other Addition to house of study & 1 bath

No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit Yes ( ) No (✓)

Auto. Dishwasher Yes (✓) No ( )

Auto. Wash. Machine Yes (✓) No ( )

Site Suitable Yes (✓) No ( )

Lot Area ½ AC.


Character & Porosity of Soil clay loam

Percolation Rate 60 mpi

Topography 5% slope

Depth to Water Table unk.

Rock or other impervious formations none ob.



Plot of System

Size of Tank 1000 Gals.

Nitrification Field:

No. of Lines 2

Sq. Ft. 600 Linear Ft. 200

Depth of Stone in Lines 10"

Water Supply: Individual (✓)

Public ( )

Installed by Lee Lackey

IMPROVEMENTS PERMIT BY John Houston

COMMENTS: Existing system ok at time of inspection. A study and 1 bath to be added to house.

CERTIFICATE OF COMPLETION BY Harold R. Hinson DATE March 6, 1979

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold