DEPARTMENT OF ENVIRONMENT,
HEALTH, & NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH

SHEET ___ OF ___
PROPERTY I.D.#: ___
PROPERTY RECORDED: ___
COUNTY: ___

SOIL/SITE EVALUATION
FOR
ON-SITE WASTEWATER SYSTEM

APPLICANT: Roy Longkta / Laura Tucker OWNER: ___ AGENT: X PHONE: ___
ADDRESS: ___ APPLICATION DATE: ___ DATE EVALUATED: 7/26/94
PROPOSED FACILITY: 4 bedroom SF Dwelling
PROPERTY SIZE: ___
LOCATION OF SITE: lot 74, Woodland Hills - at end of Broadbill Dr Rt
WATER SUPPLY: On-Site Well ___ Comm. Well ✓ Public ___ Other ___ EVAL. METHOD: Auger Boring ✓

PROFILE #	.1940 LANDSCP POS. (%)	HORIZON DEPTH (IN.)	.1941 STRUCTURE/TEXTURE	.1941 MINERALOGY/ CONSISTENCE	.1942 WETNESS COND.	.1944 RESTRICT HORIZONS	.1948 CLASS OF HORIZ	1943/ 1956 SAPRLT CLASS	HORIZON LTAR
1	LS 6-8%	0-7	gr - sl	1:1 / vfr-fr					.6
		7-17	sab - scl	1:1 / fr-fi					.5
		17-38	sab - sc	1:1 / fi-vfi					.3
		38-47+	wk sab - sic	1:1 / fi					.3
2									
3									
4									
5									

AVAILABLE SPACE (.1941): LL SITE CLASSIFICATION (.1948): LL X SITE LONG-TERM ACCEPTANCE RATE .3
EVALUATED BY: DHutmoser IRS OTHER(S) PRESENT: Laura Tucker
COMMENTS: Site can be reclassified PS per rule .1956, modified systems PPBPS. Site platted & recorded prior to 1983

Approx 10' Ground Elevation difference from backside of house to upper lot line