4446-04-9544

IREDELL COUNTY HEALTH DEPARTMENT

Mrsvl EH office

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Richard Ferrell DATE 12-19-74 PERMIT NO. 339

PHONE: Business _____ Home 596-1040

LOCATION 1100 TL on 1179 Crystal Bay

S. R. No. 1179

SUBDIVISION NAME Crystal Bay LOT NO. 34 SECTION OR BLOCK NO. —

Site Address: 215 Crystal Circle – Mrsvl

House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 2½

Garbage Disposal Unit	Yes ( )	No (✓)	
Auto. Dishwasher	Yes (✓)	No ( )	
Auto. Wash. Machine	Yes (✓)	No ( )	
Site Suitable	Yes (✓)	No ( )	

Lot Area ½ acre


Character & Porosity of Soil Existing System

Percolation Rate _____

Topography _____

Depth to Water Table _____

Rock or other impervious formations _____



Plot of System

Existing
Size of Tank 1000 Gals.

Nitrification Field:
No. of Lines 3
Sq. Ft. 562½ Linear Ft. 225
Depth of Stone in Lines 8"

Water Supply: Individual (✓)
Public ( )

Installed by Thompson Brothers
6-7-71

IMPROVEMENTS PERMIT BY J. C. Moore

COMMENTS: Add washing line 5' X 50' with 2 lines and pit at end to bring existing system up to standards for this size house

CERTIFICATE OF COMPLETION BY J. C. Moore DATE 12-19-7[illegible]

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold