DEPARTMENT OF ENVIRONMENT, HEALTH, AND NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

Sheet 1 of 2
PROPERTY ID #:
COUNTY: Terrell

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

OWNER: Jeff Terrell APPLICANT: Same
ADDRESS: APPLICATION DATE: 7/21/97 DATE EVALUATED: Same
PROPOSED FACILITY: Residential PROPOSED DESIGN FLOW (.1949): 480 GPD PROPERTY SIZE:
LOCATION OF SITE: Crystal Circle PROPERTY RECORDED:
WATER SUPPLY: ☑ Private ☐ Public ☐ Well ☐ Spring ☐ Other
EVALUATION METHOD: ☑ Auger Boring ☐ Pit ☐ Cut
TYPE OF WASTEWATER: ☑ Sewage ☐ Industrial Process ☐ Mixed

PROFILE #	.1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) .1941 STRUCTURE/ TEXTURE	SOIL MORPHOLOGY (.1941) .1941 CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	.1956 SAPRO CLASS	.1944 RESTR HORIZ	PROFILE CLASS & LTAR
1	~~0~~ 2-4%	0-6	scl gr	FRI SS SP					PS .3
		6-12	RC SBK	FI SP					
		12-48	RCL MSBK	FRI SS SP					
2	✓	0-4	scl gr	FRI SS SP					PS .3
		4-8	RC SBK	FI SP					
		8-48	RCL MSBK	FRI SS SP					
3									
4									

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)	800 50%	20%
System Type(s)	Conv Panel	Panel
Site LTAR	.3	

OTHER FACTORS (.1946):
SITE CLASSIFICATION (.1948): PS
EVALUATED BY: Bob Freeman
OTHER(S) PRESENT: Jeff Terrell, Jacob Terrell

2
240
2
480
40