ON-SITE WASTEWATER SECTION

COUNTY: _____

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

OWNER: Don Wimbish APPLICANT: _____

ADDRESS: _____ APPLICATION DATE: _____ DATE EVALUATED: 5/31/2000

PROPOSED FACILITY: _____ PROPOSED DESIGN FLOW (.1949): _____ PROPERTY SIZE: _____

LOCATION OF SITE: Crystal Bay Lot #69 PROPERTY RECORDED: _____

WATER SUPPLY: ☐ Private ☐ Public ☐ Well ☐ Spring ☐ Other _____

EVALUATION METHOD: ☐ Auger Boring ☐ Pit ☐ Cut

TYPE OF WASTEWATER: ☐ Sewage ☐ Industrial Process ☐ Mixed

PROFILE #	.1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) .1941 STRUCTURE/ TEXTURE	.1941 CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	.1956 SAPRO CLASS	.1944 RESTR HORIZ	PROFILE CLASS & LTAR
1		0-8"	Brn SCL GR FR						PS .3
		8-24"	Rd/Brn C/CL m-c SBK SS,SP,SE				F-FR		
		24-48"	Rd/Brn C/CL m-c SBK SS,SP,SE				FR w/some		
			Mica & SHP Fragms						
2		0-6"	Brn SCL GR FR						PS .3
		6-22"	Rd/Brn C/CL m-c SBK SS,SP,SE				F-FR		
		22-48"	Rd/Brn C/CL m-c SBK SS,SP,SE				FR w/Mica		
			& some SHP Fragms						
3									
4									

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)		
System Type(s)		
Site LTAR		

OTHER FACTORS (.1946): _____

SITE CLASSIFICATION (.1948): _____

EVALUATED BY: _____

OTHER(S) PRESENT: _____