4646-05-1482

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Tom Euston DATE 3-13-79 PERMIT NO. 56

PHONE: Business _____ Home _____

LOCATION 1100 TL on 1179 1st Dirt St TL 1st Paved Rd TR ½ mi on right

S. R. No. _____


SUBDIVISION NAME Crystal Bay LOT NO. 60 SECTION OR BLOCK NO. _____

House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit	Yes ( )	No (✓)	Character & Porosity of Soil	Clay loam
Auto. Dishwasher	Yes (✓)	No ( )	Percolation Rate	60 min/in
Auto. Wash. Machine	Yes (✓)	No ( )	Topography	4 to Steep
Site Suitable	Yes (✓)	No ( )	Depth to Water Table	10+
			Rock or other impervious formations	None

Lot Area ½ ac



Plot of System

Size of Tank 1000 Gals.

Nitrification Field:
No. of Lines 3
Sq. Ft. 600 Linear Ft. 200
Depth of Stone in Lines 10"

Water Supply: Individual (✓)
Public ( )

Installed by Hoke Brothers Septic Tank

IMPROVEMENTS PERMIT BY _____

COMMENTS: _____

CERTIFICATE OF COMPLETION BY John Houston DATE 3-13-79

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold