4646-05-4896

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Robert C. Cashion DATE 1-31-79 PERMIT NO. 28

PHONE: Business 664-5115 Home _____

LOCATION 1100 TL on 1179 TL on 1207 on 1207 ½ mi on right S. R. No. _____


SUBDIVISION NAME Crystal Bay LOT NO. 5 SECTION OR BLOCK NO. _____

House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 2 No. Bathrooms 2

Garbage Disposal Unit	Yes (✓)	No ( )	Character & Porosity of Soil	Clay loam
Auto. Dishwasher	Yes (✓)	No ( )	Percolation Rate	60 min/in
Auto. Wash. Machine	Yes (✓)	No ( )	Topography	5% Slope
Site Suitable	Yes (✓)	No ( )	Depth to Water Table	6' to 8'
			Rock or other impervious formations	None

Lot Area ½ ac



Plot of System

Size of Tank 1250 Gals.

Nitrification Field:
No. of Lines 3
Sq. Ft. 600 Linear Ft. 200
Depth of Stone in Lines 10"

Water Supply: Individual (✓)
Public ( )

Installed by J. R. Bowles

IMPROVEMENTS PERMIT BY _____

COMMENTS: _____

CERTIFICATE OF COMPLETION BY John Houston DATE 1-31-79

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold