4646-06
7936

IREDELL COUNTY HEALTH DEPARTMENT

09563

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Larry Heim DATE Dec. 13, '90 PERMIT NO. 2K-2-B6

PHONE: Business _____ Home _____

LOCATION 1100 TR 1179 (Canvasback) TR 1st Woodduck Loop ~½ mile on Right S. R. No. _____

SUBDIVISION NAME Lakes Lore Estates LOT NO. Lot #2 SECTION OR BLOCK NO. 11

House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 2½

Garbage Disposal Unit Yes (✓) No ( )

Auto. Dishwasher Yes (✓) No ( )

Auto. Wash. Machine Yes (✓) No ( )

Site ~~Suitable~~ PS Yes (✓) No ( )

Lot Area ½ Ac + (Existing - not subject to 100% required repair area) (PARTIAL)

Character & Porosity of Soil Sandy


Percolation Rate 40.35

Topography 10-15%

Depth to Water Table 6'+

Rock or other impervious formations none obs.

_____ Basement with Plumbing _____ Basement without Plumbing _____ No Basement



Plot of System

Size of Tank 1250 Gals.

Nitrification Field:
No. of Lines 7
Sq. Ft. 1029 Linear Ft. 343
Depth of Stone in Lines 12"

Water Supply: Individual (✓) (not installed yet)
Public ( )

Installed by F J Erwin

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: _____

IMPROVEMENTS PERMIT BY ACP

COMMENTS: Well not installed. Entrance to garage changed from IP making it necessary for more (and shorter) lines.

CERTIFICATE OF COMPLETION BY [signature] Mason, EHS DATE 12-13-90

EXISTING SYSTEM CHECKED BY: _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold