4646076154

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Tommy & Marsha Chester DATE 10/26/87 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION 1100 TL Canvas Back TL 1st Woodduck
~1/2 mile on R in Curve. S. R. No. _____

SUBDIVISION NAME Lakeshore Estates LOT NO. 13 SECTION OR BLOCK NO. _____


House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 2
Garbage Disposal Unit Yes ( ) No (✓)
Auto. Dishwasher Yes (✓) No ( )
Auto. Wash. Machine Yes (✓) No ( )
Site Suitable Yes (✓) No ( )

Character & Porosity of Soil clay
Percolation Rate .4gal/ft²/day
Topography 2-8%
Depth to Water Table 4'
Rock or other impervious formations none observed

Lot Area .42 ACRES

_____ Basement with Plumbing _____ Basement without Plumbing ✓ No Basement



Plot of System NTS

Size of Tank 1000 Gals.
Nitrification Field:
No. of Lines 5
Sq. Ft. 900 Linear Ft. 300
Depth of Stone in Lines 12"
Water Supply: Individual (✓)
Public ( )

Installed by F.J. ERVIN

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: F.J. Ervin

IMPROVEMENTS PERMIT BY Charles K. Barnette R.S.

COMMENTS: _____

The proposed / ~~existing~~ Pool addition does not appear to impact the existing septic system.

**NOTE: _____

Cindy Melville R.S.
Date: 12-11-09
ICHD-Environmental Health Division

CERTIFICATE OF COMPLETION BY Andrew C. Queen DATE _____

EXISTING SYSTEM CHECKED BY: _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold