PERMIT TO INSTALL SEPTIC TANK

Permit NO. _____ Permit Date 23 Sept 1970

Owner Regency Lake Address Mooresville, N.C.

Installed By Wesson Address Shelby, N.C.

Location of Property Lot 5 Block B

Tank		Capacity		Length of Lines		Fixtures	
Block	( )	1000	(✓)	225'	(✓)	No. of Baths	( )
Precast	(✓)	1250	( )	250'	( )	Dishwasher	( )
		1500	( )	Other _____		Garbage Grdr.	( )
		Other _____				Other _____	

NOTIFY HEALTH DEPARTMENT AT LEAST EIGHT HOURS BEFORE TANK IS TO BE INSPECTED.

Final Inspection 23 Sept 1970 Approved (✓) Disapproved ( )

Remarks _____

