IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR John Gwissinger DATE 5-21-75 PERMIT NO. 104

PHONE: Business _____ Home 597-8180

LOCATION 1100 TL on 1st Paved Rd to left TL on 1229 on left S. R. No. 1227

SUBDIVISION NAME Regency Lake LOT NO. 14 SECTION OR BLOCK NO. A


House ( ) Mobile Home (✓) Business ( ) Other _____

No. Bedrooms 2 No. Bathrooms 1

Garbage Disposal Unit	Yes ( )	No (✓)	
Auto. Dishwasher	Yes ( )	No (✓)	
Auto. Wash. Machine	Yes (✓)	No ( )	
Site Suitable	Yes (✓)	No ( )	

Lot Area ½ acre

Character & Porosity of Soil Clay loam Porosity Fair
Percolation Rate Not taken
Topography 2 20% slope
Depth to Water Table 10'
Rock or other impervious formations None



Plot of System

Size of Tank 1000 Gals.
Nitrification Field:
No. of Lines 3
Sq. Ft. 680 Linear Ft. 253
Depth of Stone in Lines 10
Water Supply: Individual ( )
Public (✓)
Regency Lake water system
Installed by F. J. Ervin

IMPROVEMENTS PERMIT BY John Houston

COMMENTS: _____

CERTIFICATE OF COMPLETION BY J. C. Moore DATE 5-21-75

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold