IREDELL COUNTY HEALTH DEPARTMENT 4646-09-4556

12240

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Smith Builders DATE 3/27/91 PERMIT NO. 2K-19-A-21

PHONE: Business _____ Home 664-1704

LOCATION Farmstead, Brawley School TL with Farmstead TR 1st Street to Blue brick on (R), next to last before cul de sac

SUBDIVISION NAME Farmstead LOT NO. 21 SECTION OR BLOCK NO. _____ S. R. No. _____


House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms _____ No. Bathrooms _____

Garbage Disposal Unit	Yes ( )	No (✓)	Character & Porosity of Soil	PA clay
Auto. Dishwasher	Yes ( )	No (✓)	Percolation Rate	.4
Auto. Wash. Machine	Yes (✓)	No ( )	Topography	2-4%
Site Suitable	Yes (✓)	No ( )	Depth to Water Table	>48"
			Rock or other impervious formations	none obs.

Lot Area 20,000 FT²

_____ Basement with Plumbing _____ Basement without Plumbing _____ No Basement



Plot of System

Size of Tank 1000 Gals.

Nitrification Field:
No. of Lines 3
Sq. Ft. 900 Linear Ft. 300
Depth of Stone in Lines 12"

Water Supply: Individual (✓)
Public ( )

Installed by Allen Smith

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: _____

IMPROVEMENTS PERMIT BY _____

COMMENTS: _____

CERTIFICATE OF COMPLETION BY Wesley Sparks RS DATE 3/27/91

EXISTING SYSTEM CHECKED BY: _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold