15812

IREDELL COUNTY HEALTH DEPARTMENT

IMPROVEMENT PERMIT AND CERTIFICATE OF COMPLETION / OPERATIONS PERMIT

OWNER OR CONTRACTOR JAMES GREENE DATE 4-2-93 PERMIT NO. 2K-7-D-2

PHONE: Business _____ Home 664-7652 110 KENNERLY AVE. MOORESVILLE, N.C. 28115

LOCATION ON North side of Regency RD ~200' West FROM SR 1228

S.R. No. 1226

SUBDIVISION NAME Regency Lake Village LOT NO. 2 SECTION OR BLOCK NO. D

House ☑ Mobile Home ☐ Business ☐ Other _____

No. Bedrooms 2 No. Bathrooms 2

Garbage Disposal Unit Yes ☐ No ☒

Auto. Dishwasher Yes ☑ No ☐

Auto. Wash. Machine Yes ☑ No ☐

Lot Area 16,150 SQ FT

Soil Characteristics PS clay-SILTY CLAY / WK MED SBK / dsh


Application Rate LTAR 0.3 - 0.25

Topography S <15%, Regular

Depth to Water Table S >40"

Rock or other impervious formations S >48"

_____ Basement with Plumbing _____ Basement without Plumbing _____ No Basement ✓ Crawl Space



Plot of System

Size of Tank 900 MINIMUM Gals.

Nitrification Field:

No. of Lines 5

Sq. Ft. 870 Linear Ft. 290'

Depth of Stone in Lines 12" (6" UNDER PIPE)

Water Supply: Individual ☐ Public ☑

Installed by _____

I understand and agree to install a septic tank system as specified on this Improvement Permit.

Signed: James H Greene

(IMPROVEMENT PERMIT IS VALID FOR 60 MONTHS FROM DATE OF ISSUE.)

IMPROVEMENT PERMIT BY Andrea Lema RS

COMMENTS FOLLOW CONTOUR - 20" TRENCH BOTTOM DEPTH THROUGHOUT SYSTEM. DIVIDE EFFLUENT FROM TANK WITH FLOW DIVIDER/DIRECTOR TEE, THEN W/ BOX OR TEE TO UPPER SET (2) OF LINES & W/ BOX TO LOWER SET (3) OF LINES. MAINTAIN 15' TO TOP OF ENBANKMENT ALONG ROAD DITCH. DO NOT INSTALL IN WET SOIL OR DURING RAIN. CALL IF THERE ARE ANY QUESTIONS.

CERTIFICATE OF COMPLETION BY _____ DATE _____

EXISTING SYSTEM CHECKED BY _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS

Permit is VOID if any unauthorized changes are made in installation of system, and/or if any unapproved changes are made to the site, and/or if any false information is supplied toward securing Improvement Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold