IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Jim Frye DATE 11-6-75 PERMIT NO. 250

PHONE: Business 664-2525 Home

LOCATION US21 S 1st Rd to Left after 1st TR on 1193 TR on 1195 at end.

SUBDIVISION NAME S. R. No.

LOT NO. SECTION OR BLOCK NO.


House (X) Mobile Home ( ) Business ( ) Other

No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit	Yes ( )	No (X)
Auto. Dishwasher	Yes (X)	No ( )
Auto. Wash. Machine	Yes (X)	No ( )
Site Suitable	Yes (X)	No ( )

Lot Area 120 X 150

Character & Porosity of Soil Clay loam Permit Pair
Percolation Rate 1pi Taken
Topography 2% to 3%, Slope
Depth to Water Table 8' to 20', Lake Level
Rock or other impervious formations None



Plot of System

Size of Tank 1000 Gals.
Nitrification Field:
No. of Lines 5
Sq. Ft. 625 Linear Ft. 250
Depth of Stone in Lines 10
Water Supply: Individual (X)
Public ( )

Installed by E.J. Ervin

IMPROVEMENTS PERMIT BY John Houston

COMMENTS: Well not put in place when locate on Improvement permit

CERTIFICATE OF COMPLETION BY John Houston DATE 11-6-75

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold