PIN 4646 12 9469

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Phil E. Lipe II DATE 4-14-82 PERMIT NO. 88

PHONE: Business _____ Home _____

LOCATION 215 S. X I77 TR 1206 TR 1110 Bear Rt 1193 TR 1494. ~3 mile on Rt.

SUBDIVISION NAME Catalina Cove LOT NO. 17 S. R. No. _____


Back Forty SECTION OR BLOCK NO. _____

House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 2 No. Bathrooms 1½

Garbage Disposal Unit	Yes ( )	No	(✓)	Character & Porosity of Soil clay loam
Auto. Dishwasher	Yes (✓)	No	( )	Percolation Rate 4-8
Auto. Wash. Machine	Yes (✓)	No	( )	Topography Hilly
Site Suitable	Yes (✓)	No	( )	Depth to Water Table unk. 4'+
Lot Area 100' X 200'				Rock or other impervious formations none obs.

_____ Basement with Plumbing ✓ Basement without Plumbing _____ No Basement



Plot of System

Size of Tank 1000 Gals.

Nitrification Field:
No. of Lines 4
Sq. Ft. 250 Linear Ft. 250
Depth of Stone in Lines 6"

Water Supply: Individual (✓)
Public ( )

Installed by Ronnie Donaldson Lincoln Co.

I understand and agree to install septic tank system as specified on this Improvements Permit.

The location of the proposed Bath Addition addition does not appear to impact the existing septic system.
**NOTE: Expanding full bath

Judy Melville REHS
Date: 12-1-11
ICHD-Environmental Health Division

IMPROVEMENTS PERMIT BY _____

The proposed / existing Decks addition does not appear to impact the existing septic system.
**NOTE: Must be 25' from well min.

Judy Melville REHS
Date: 8-31-11 8-31-11
ICHD-Environmental Health Division

COMMENTS: _____

CERTIFICATE OF COMPLETION BY _____ DATE _____

EXISTING SYSTEM CHECKED BY: David K. Johnson DATE 4-14-82

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.
Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold