07308

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION

(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Thomas Katasanos DATE Feb 1, '89 PERMIT NO. 4646-15-1788

PHONE: Business _____ Home _____

LOCATION 1100 to 1179 to 2nd Wood Duck Loop ½ mile on Rt. S. R. No. _____

SUBDIVISION NAME Lakeshore Estates LOT NO. 37 SECTION OR BLOCK NO. _____

House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 2-3 Character & Porosity of Soil clay

Garbage Disposal Unit Yes ( ) No (✓) Percolation Rate ~.3


Auto. Dishwasher Yes (✓) No ( ) Topography 2-4%

Auto. Wash. Machine Yes (✓) No ( ) Depth to Water Table 4'+

Site Suitable PS Yes (✓) No ( ) Rock or other impervious formations none obs.

Lot Area 41'(Road) 30' LS, 235 RS, 180' water

_____ Basement with Plumbing _____ Basement without Plumbing ✓ No Basement



Plot of System

1000 p.t.

Size of Tank 1000 Gals.

Nitrification Field:

No. of Lines 5

Sq. Ft. _____ Linear Ft. 200'

Depth of Stone in Lines 16" 7"

Water Supply: Individual (✓) panels pressurized

Public ( )

Installed by J Ferrin

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: _____

IMPROVEMENTS PERMIT BY DRH

COMMENTS: Alarm checked & OK but not mounted

CERTIFICATE OF COMPLETION BY J Ferrin, RS DATE 1-1-89

EXISTING SYSTEM CHECKED BY: _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold