07308

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION

(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Thomas Katsamas DATE Sept. 10, '87 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION 1100 TR 1179 (Cowans back) TR 2nd entrance on Woodduck Loop ON Rt. in curve S. R. No. _____

SUBDIVISION NAME Lakeshore Estates LOT NO. 37 SECTION OR BLOCK NO. _____

House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 2-3

Garbage Disposal Unit	Yes ( )	No (✓)	
Auto. Dishwasher	Yes (✓)	No ( )	
Auto. Wash. Machine	Yes (✓)	No ( )	
Site Suitable	Yes (✓)	No ( )	

Character & Porosity of Soil clay

Percolation Rate 2, 4


Topography 2-4% 4+7

Depth to Water Table _____

Rock or other impervious formations NONE OBS.

Lot Area 41' (road), 301' (L. side), 235' (R. side), 180' (water)

_____ Basement with Plumbing _____ Basement without Plumbing ✓ No Basement



Plot of System

1000 gal pump tank

Size of Tank 1000 Gals.

Nitrification Field:

No. of Lines ~4

Sq. Ft. _____ Linear Ft. 200' of

Depth of Stone in Lines 16" T & F

Water Supply: Individual (✓) Public ( )

panels — pressure dosed

Installed by _____

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: Rick Dobin
For Tom Katsamas

IMPROVEMENTS PERMIT BY David R. Upton, R.S.

COMMENTS: Follow contour with panels, install panels no deeper than 30" to bottom of ditch.

CERTIFICATE OF COMPLETION BY _____ DATE _____

EXISTING SYSTEM CHECKED BY: _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold