13895

IREDELL COUNTY HEALTH DEPARTMENT

4646-15 2856

IMPROVEMENT PERMIT AND CERTIFICATE OF COMPLETION / OPERATIONS PERMIT

OWNER OR CONTRACTOR Thad Campbell DATE 1/22/92 PERMIT NO. 2K-2A-36

PHONE: Business _____ Home 399-2224

LOCATION Woodduck Loop - Conoestoga, TL on 1st Woodduck to 2nd shop lane, (R) on drive to brick home S.R. No. _____

SUBDIVISION NAME Lakeshore Est. LOT NO. 36 SECTION OR BLOCK NO. _____

House ☑ Mobile Home ☐ Business ☐ Other building garage Existing System

No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit Yes ☐ No ☑

Auto. Dishwasher Yes ☑ No ☐

Auto. Wash. Machine Yes ☑ No ☐

Lot Area 20,000 FT²

Soil Characteristics _____


Application Rate _____

Topography _____

Depth to Water Table _____

Rock or other impervious formations _____

_____ Basement with Plumbing _____ Basement without Plumbing _____ No Basement ☑ Crawl Space



Plot of System (Not to Scale)

Size of Tank 1500 Gals.

Nitrification Field:

No. of Lines 72' x 15' Bed

Sq. Ft. 1080 Linear Ft. 360

Depth of Stone in Lines 12"

Water Supply: Individual ☑ Public ☐

Installed by Leon Thompson

I understand and agree to install a septic tank system as specified on this Improvement Permit.

Signed: _____

(IMPROVEMENT PERMIT IS VALID FOR 60 MONTHS FROM DATE OF ISSUE.)

IMPROVEMENT PERMIT BY _____

COMMENTS No visible evidence of malfunction. Garage needs to be moved 15' further up slope from where it is staked out.

CERTIFICATE OF COMPLETION BY _____ DATE _____

EXISTING SYSTEM CHECKED BY Wesley Sparks RS. DATE 1/22/92

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS

Permit is VOID if any unauthorized changes are made in installation of system, and/or if any unapproved changes are made to the site, and/or if any false information is supplied toward securing Improvement Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold