4604015294

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Meredith V. Dawson DATE 11-10-78 PERMIT NO. 276

PHONE: Business _____ Home 664-5931

LOCATION 1100 TL on 1179 2nd Left

S. R. No. _____

SUBDIVISION NAME Lakeshore Estates LOT NO. 35 SECTION OR BLOCK NO. _____

House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit	Yes	(✓)	No	( )	
Auto. Dishwasher	Yes	(✓)	No	( )	
Auto. Wash. Machine	Yes	(✓)	No	( )	
Site Suitable	Yes	(✓)	No	( )	

Character & Porosity of Soil Clay loam


Percolation Rate 60 min.

Topography 2 to 5% slope

Depth to Water Table 6' to 8'

Rock or other impervious formations None

Lot Area ½ ac



Plot of System

Size of Tank Existing Gals.

Nitrification Field:
No. of Lines 2
Sq. Ft. 240 Linear Ft. 80
Depth of Stone in Lines 16"

Water Supply: Individual (✓)
Public ( )

Installed by J.R. Bowles

IMPROVEMENTS PERMIT BY _____

COMMENTS: _____

CERTIFICATE OF COMPLETION BY John Houston DATE 11-9-78

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold