VISION OF ENVIRONMENTAL HEALTH
I-SITE WASTEWATER SECTION

PROPERTY ID
COUNTY: ____

# SOIL/SITE EVALUATION
## *for* ON-SITE WASTEWATER SYSTEM

OWNER: Doug Pierce — APPLICANT: ____
ADDRESS: ____ APPLICATION DATE: ____ DATE EVALUATED: ____
PROPOSED FACILITY: House — PROPOSED DESIGN FLOW (.1949): 360 — PROPERTY SIZE: ____
LOCATION OF SITE: Lot 32 Lakeside Farms — PROPERTY RECORDED: ____
WATER SUPPLY: ☐ Private ☒ Public ☐ Well ☐ Spring ☐ Other ____
EVALUATION METHOD: ☒ Auger Boring ☐ Pit ☐ Cut
TYPE OF WASTEWATER: ☒ Sewage ☐ Industrial Process ☐ Mixed

| .1940 LANDSCAPE POSITION/ SLOPE % | HORIZON DEPTH (IN.) | SOIL MORPHOLOGY (.1941) .1941 STRUCTURE/ TEXTURE | .1941 CONSISTENCE/ MINERALOGY | OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR | .1943 SOIL DEPTH | .1956 SAPRO CLASS | .1944 RESTR HORIZ | PROFILE CLASS & LTAR |
|---|---|---|---|---|---|---|---|---|
| 1 nd | 0-10 | FrsbK / L | Fr / SS v NP | BR/DRY | | | | |
| | 11-19 | sbK / cl | Fm / SS - SP | R/DRY | | | | |
| | 20-29 | MsbK / C | Fi / SS - SP | OH-3 35" MR | | | | .25 |
| | 30-49 | wk sbK / C | FFR SS - SP | MR CH3 | | | | .2 |
| | | | | | | | | |
| 2 nd | 0-4 | GR / Full | | | | | GRAVELY | |
| | 5-16 | sbK / C | Fi / S - SP | | | | | .25 |
| | 17-30 | sbK / C | Fi / SS - SP | | | | | |
| | 31-46 | FrsbK / cl SAP | FR / SS - SP | MR WET | | | | |
| | 41-49 | FR FRIABLE SAP | VFR / SS - SP | | | | | .35 |
| | | | | | | | | |
| | | | | | | | | |
| | | | | | | | | |
| | | | | | | | | |
| | | | | | | | | |
| | | | | | | | | |
| | | | | | | | | |
| | | | | | | | | |
| | | | | | | | | |
| | | | | | | | | |

| DESCRIPTION | INITIAL SYSTEM | REPAIR SYSTEM |
|---|---|---|
| Suitable Space (.1945) | PS | Back Yard Primary |
| System Type(s) | 16" PPBDS | Spare |
| LTAR | | |

OTHER FACTORS (.1946): Mobile Home - 16" PPBPS
SITE CLASSIFICATION (.1948): ____
SYSTEM ATTACHED: ____
OTHER(S) PRESENT: ____