...ISION OF ENVIRONMENTAL HEALTH
...-SITE WASTEWATER SECTION

PROPERTY ID #: _____
COUNTY: _____

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

...ER: Mark Hall
...DRESS: _____ Sundown Rd APPLICANT: _____
...OPOSED FACILITY: _____ APPLICATION DATE: _____ DATE EVALUATED: 5/1/03
...CATION OF SITE: _____ PROPOSED DESIGN FLOW (.1949): _____ PROPERTY SIZE: _____
...TER SUPPLY: ☒ Private ☐ Public ☐ Well ☐ Spring ☐ Other _____ PROPERTY RECORDED: _____
...ALUATION METHOD: ☒ Auger Boring ☐ Pit ☐ Cut
...PE OF WASTEWATER: ☒ Sewage ☐ Industrial Process ☐ Mixed

.1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) .1941 STRUCTURE/ TEXTURE	.1941 CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	.1956 SAPRO CLASS	.1944 RESTR HORIZ	PROFILE CLASS & LTAR
	0-4"	Brn SL	GR FR					
	4-45"	Rd/Brn C/CL, m-w SBK SS, SP, SE, FFR w/ some Mica						PS, 3 to 45"
	45"	Rd/Brn C * Yel/Brn SAP? Mix						
★ Replacing existing Septic System with new system.								

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
...ilable Space (.1945)		
...em Type(s)		
LTAR		

OTHER FACTORS (.1946): _____
SITE CLASSIFICATION (.1948): _____

EVALUATED BY: _____
OTHER(S) PRESENT: _____