4646-18-1710

II

12584

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Roger McGaffey DATE May 31, 91 PERMIT NO. 2K-7-A-17

PHONE: Business _____ Home _____

LOCATION 1100 TL 1179 TL Regency Blvd. TR Hazelton Dr. ~100' on left S. R. No. _____

SUBDIVISION NAME Regency Lake Village LOT NO. 17 SECTION OR BLOCK NO. A


House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit Yes (✓) No ( )
Auto. Dishwasher Yes (✓) No ( )
Auto. Wash. Machine Yes (✓) No ( )
Site ~~Suitable~~ RS Yes ( ) No ( )
Lot Area ~~100'X230'+~~ ✓

Character & Porosity of Soil PS clay
Percolation Rate ~3
Topography ~6-8%
Depth to Water Table 4'+
Rock or other impervious formations none obs.

_____ Basement with Plumbing _____ Basement without Plumbing _____ No Basement



Plot of System

Size of Tank 1250 Gals.
Nitrification Field:
No. of Lines 3
Sq. Ft. _____ Linear Ft. 200' 18" 16" 20
Depth of Stone in Lines _____
Water Supply: Individual ( ) Public (✓) County Flow
Installed by: J R Bowles

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: _____

IMPROVEMENTS PERMIT BY DRH Embankment

COMMENTS: water line not installed yet.

CERTIFICATE OF COMPLETION BY Jack Hoffman, RS DATE 5/31/91

EXISTING SYSTEM CHECKED BY: _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold