DEPARTMENT OF ENVIRONMENT,
HEALTH, & NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH


SHEET 1 OF 1
PROPERTY I.D.#: 2K 7418
PROPERTY RECORDED: YES
COUNTY: Haywood

SOIL/SITE EVALUATION
FOR
ON-SITE WASTEWATER SYSTEM

APPLICANT: Wm. Kenyon OWNER: AGENT: PHONE:
ADDRESS: Lot 18 Regency Lake APPLICATION DATE: 8/12/93 DATE EVALUATED: 8/12/93
PROPOSED FACILITY: 3 bedroom SF Dwelling
PROPERTY SIZE: 100'X ± 246'
LOCATION OF SITE: Hazelton Loop ~ 1100', TR 1179, TR Regency Rd, TR Hazelton 50' on left
WATER SUPPLY: On-Site Well___ Comm. Well___ Public ✓ Other_____ EVAL. METHOD: Auger Boring ✓ Pit___ Cut___

PROFILE #	.1940 LANDSCP POS. (%)	HORIZON DEPTH (IN.)	.1941 STRUCTURE/TEXTURE	.1941 MINERALOGY/ CONSISTENCE	.1942 WETNESS COND.	.1944 RESTRICT HORIZONS	.1948 CLASS OF HORIZ	1943/ 1956 SAPRLT CLASS.	HORIZON LTAR
1	SS	0-10"	sbk / c	1:1 / fi	—	—	PS	—	.4
		10-40"	wk sbk / sicl	1:1 / fr	—	—	PS	—	.25-.3
2	SS	0-4"	gr / scl	1:1 / fr.	—	—	PS	—	.5
		4-30"	sbk / c	1:1 / fr	—	—	PS	—	.4
		30-40"	wk sbk / cl	1:1 / fr	—	—	PS	—	.3
3	SS	0-3	gr / cl	1:1 / fr.	—	—	PS	—	.4-.5
		3-28	sbk / c	1:1 / fr	—	—	PS	—	.35-.4
		28-47"	wk sbk / cl	1:1 / fr	—	—	PS	—	.3
4									
5									

AVAILABLE SPACE (.1941) PS SITE CLASSIFICATION (.1948): PS SITE LONG-TERM ACCEPTANCE RATE: .3
EVALUATED BY: DR Johnson OTHER(S) PRESENT: Wm Kenyon
COMMENTS: Install trenches at 24" to depth.


Lake
~120'
1
2
3
PL
PL
Hazelton Lp