DEPARTMENT OF ENVIRONMENT,
HEALTH, & NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH

SHEET ___ OF ___
PROPERTY I.D.#: ___
PROPERTY RECORDED: ___
COUNTY: ___

SOIL/SITE EVALUATION
FOR
ON-SITE WASTEWATER SYSTEM

APPLICANT: John Corriher OWNER: AGENT: PHONE: ___
ADDRESS: ___ APPLICATION DATE: ___ DATE EVALUATED: 10/5/fk
PROPOSED FACILITY: ___
PROPERTY SIZE: ___
LOCATION OF SITE: lot 45 Farmstead
WATER SUPPLY: On-Site Well ✓ Comm. Well ___ Public ___ Other ___ EVAL. METHOD: Auger Boring ✓ Pit ___ Cut ___

PROFILE #	.1940 LANDSCP POS. (%)	HORIZON DEPTH (IN.)	.1941 STRUCTURE/TEXTURE	.1941 MINERALOGY/ CONSISTENCE	.1942 WETNESS COND.	.1944 RESTRICT HORIZONS	.1948 CLASS OF HORIZ	1943/ 1956 SAPRLT CLASS.	HORIZON LTAR
1		0-9	gr- scL	1:1 /fr			PS		.25
		9-24	SAB- C	1:1 /fi-vfi					
		24-42	wk SAB- SiC	1:1					
		42+	SAP						
2		0-9	gr/SAB/scL	1:1 /fr					.25
		9-24	SAB / C	1:1 /fi-vfi					
		24-48	wk SAB/ SiC	1:1 /fi					
		48+	SAP						
3									
4									
5									

AVAILABLE SPACE (.1945) ___ SITE CLASSIFICATION (.1948): ___ SITE LONG-TERM ACCEPTANCE RATE: .25

EVALUATED BY: ___ OTHER(S) PRESENT: ___

COMMENTS: ___