DEPARTMENT OF ENVIRONMENT, HEALTH, AND NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

Sheet ___ of ___
PROPERTY ID #: _____
COUNTY: _____

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

OWNER: _____ APPLICANT: Scott Poltorak
ADDRESS: _____ APPLICATION DATE: _____ DATE EVALUATED: 12/27/95
PROPOSED FACILITY: 3BD / 2BA PROPOSED DESIGN FLOW (.1949): 360 PROPERTY SIZE: _____
LOCATION OF SITE: Catalina Rd on (L) across from Cottage Rd PROPERTY RECORDED: _____
WATER SUPPLY: ☒ Private ☐ Public ☐ Well ☐ Spring ☐ Other _____
EVALUATION METHOD: ☒ Auger Boring ☐ Pit ☐ Cut
TYPE OF WASTEWATER: ☒ Sewage ☐ Industrial Process ☐ Mixed

PROFILE #	.1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) .1941 STRUCTURE/ TEXTURE	.1941 CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	.1956 SAPRO CLASS	.1944 RESTR HORIZ	PROFILE CLASS & LTAR
1		0-7	CL gr	fri SSSP				44"	.25
		8-32	C SBK	firm SSP					
		32-38	Heavy CL SBK	fri SS,SP					
		38-44	Mottles						
			Mix Mineralogy						
2									
3									
4									

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)	PS	~ PS
System Type(s)	Trench Panel	Pressure PBBS
Site LTAR	.25	.25

OTHER FACTORS (.1946): Wells on both sides
SITE CLASSIFICATION (.1948): ~ PS
EVALUATED BY: Hicks
OTHER(S) PRESENT: B Freeman