4646 21 2053
125 Rainbow RD.
Lot 13

10367

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR John W. Tonissen DATE Mar 23, 1990 PERMIT NO. 26-5-B-13

PHONE: Business _____ Home 364-2667

LOCATION 215 x I77 TL Alcove TR Catalina TR Rainbow
On left ~ 3 houses S. R. No. _____

SUBDIVISION NAME Catalina Cove LOT NO. 13 SECTION OR BLOCK NO. _____

House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 2½

Garbage Disposal Unit	Yes	(✓)	No	( )	
Auto. Dishwasher	Yes	(✓)	No	( )	
Auto. Wash. Machine	Yes	(✓)	No	( )	
Site Suitable	Yes	(✓)	No	( )	

Character & Porosity of Soil clay
Percolation Rate .4
Topography 4%
Depth to Water Table 4'+
Rock or other impervious formations none obs

Lot Area _____

_____ Basement with Plumbing _____ Basement without Plumbing _____ No Basement

1250 P. Tank
Size of Tank 1250 Gals.


Nitrification Field:
No. of Lines 5@60
Sq. Ft. 900 Linear Ft. 300
Depth of Stone in Lines 12"

Water Supply: Individual (✓)
Public ( )

Installed by Wayne Orbison

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: _____



IMPROVEMENTS PERMIT BY _____

COMMENTS: * Well not installed at time of inspection final
Note - Change in tank location

Operation Permit

~~CERTIFICATE OF COMPLETION~~ BY Sam Ingram EHS DATE Mar 23, 1990

EXISTING SYSTEM CHECKED BY: _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold