10367

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION

(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR John W. Tonissen DATE 8/23/89 PERMIT NO. 29-S-B-13

PHONE: Business _____ Home 364-2667

LOCATION 21S. XI 77 TL Alcove TR Catalina TR

Rainbow On left ~ 3 houses S. R. No. _____


SUBDIVISION NAME Catalina Cv. LOT NO. _____ SECTION OR BLOCK NO. _____

House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms	3	No. Bathrooms	2 1/2	Character & Porosity of Soil	Clay
Garbage Disposal Unit	Yes (✓)		No ( )	Percolation Rate	4
Auto. Dishwasher	Yes (✓)		No ( )	Topography	4%
Auto. Wash. Machine	Yes (✓)		No ( )	Depth to Water Table	4'+
Site Suitable	Yes (✓)		No ( )	Rock or other impervious formations	none obs

Lot Area _____

_____ Basement with Plumbing _____ Basement without Plumbing ✓ No Basement



Plot of System

1250-P Tank

Size of Tank 1250 Gals.

Nitrification Field:
No. of Lines 5-4
Sq. Ft. 900 Linear Ft. 300
Depth of Stone in Lines 12"

Water Supply: Individual (✓)
Public ( )

Installed by _____

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: J W Tonissen

IMPROVEMENTS PERMIT BY Andrew C Price, R.S.

COMMENTS: Set tanks at required distances off house/line. Pump through Sch. 40 PVC 2" pipe line and reduce to 1¼" PVC in working lines. Use ball valves to regulate flow. Pump should deliver 2' head to each ditch Working line

CERTIFICATE OF COMPLETION BY _____ DATE _____

EXISTING SYSTEM CHECKED BY: Should have 5/32" hole every 5'. DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold