# IREDELL COUNTY HEALTH DEPARTMENT

## (SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION

(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Ricky L. Hartline DATE 10-27-75 PERMIT NO. 234

PHONE: Business _____ Home _____

LOCATION 21 South TR on 1109 TL on 1191 ½ mi on left

SUBDIVISION NAME Bonanza LOT NO. _____ SECTION OR BLOCK NO. _____ S. R. No. _____

House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 2

| | | |
|---|---|---|
| Garbage Disposal Unit | Yes (✓) | No ( ) |
| Auto. Dishwasher | Yes (✓) | No ( ) |
| Auto. Wash. Machine | Yes (✓) | No ( ) |
| Site Suitable | Yes (✓) | No ( ) |

Lot Area 98' X 205'


Character & Porosity of Soil Clay loam Porosity Fair

Percolation Rate Not taken

Topography 7 2 70 Slope

Depth to Water Table 10' +

Rock or other impervious formations None




Plot of System

Size of Tank 1500 Gals.

Nitrification Field:

No. of Lines 4

Sq. Ft. 625 Linear Ft. 250

Depth of Stone in Lines 10"

Water Supply: Individual (✓)

Public ( )

Installed by Eddie Young
Statesville, N.C.

IMPROVEMENTS PERMIT BY ~~J. C. Moore~~ John Houston

COMMENTS: Tank is 24' from foundation & Box is 23' from Tank.

CERTIFICATE OF COMPLETION BY J. C. Moore DATE 10-27-75

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold