IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Young & Lisk DATE 2-16-78 PERMIT NO. 21

PHONE: Business _____ Home _____

LOCATION 150W TL on 1101 TL on 1191

SUBDIVISION NAME Bonanza LOT NO. 17 S. R. No. _____ SECTION OR BLOCK NO. _____

House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 4 No. Bathrooms 3 1/2

Garbage Disposal Unit	Yes (✓)	No ( )	
Auto. Dishwasher	Yes (✓)	No ( )	
Auto. Wash. Machine	Yes (✓)	No ( )	
Site Suitable	Yes (✓)	No ( )	

Lot Area 1 Acre


Character & Porosity of Soil Sandy Clay loam

Percolation Rate 30 min/in

Topography Rolling

Depth to Water Table 10 ft

Rock or other impervious formations None



Plot of System

Size of Tank 1500 Gals.

Nitrification Field:
No. of Lines 4
Sq. Ft. 200 Linear Ft. 340
Depth of Stone in Lines 16

Water Supply: Individual (✓)
Public ( )

Installed by Bill Bowman

IMPROVEMENTS PERMIT BY _____

COMMENTS: _____

CERTIFICATE OF COMPLETION BY [illegible] DATE 2-

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold