4646-24-9293

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR S.D. Howard DATE 7-7-87 PERMIT NO.

PHONE: Business Home

LOCATION 1109 TR 1191 (Pondrosa) 1/2 mile on Rt.

S. R. No.

SUBDIVISION NAME Bonanza LOT NO. 14 SECTION OR BLOCK NO.

House (✓) Mobile Home ( ) Business ( ) Other


No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit	Yes ( )	No (✓)	Character & Porosity of Soil	clay	
Auto. Dishwasher	Yes (✓)	No ( )	Percolation Rate	n.s	
Auto. Wash. Machine	Yes (✓)	No ( )	Topography	20-30%	
Site Suitable	Yes (✓)	No ( )	Depth to Water Table	44	
			Rock or other impervious formations	none obs.	

Lot Area 20000 ft²

✓ Basement with Plumbing ___ Basement without Plumbing ___ No Basement

1000 gal pump tank



Plot of System

Size of Tank 1000 Gals.

Nitrification Field:
No. of Lines 4
Sq. Ft. 720 Linear Ft. 240
Depth of Stone in Lines 12"

Water Supply: Individual (✓)
Public ( )

Installed by Max Caldwell
Lincoln County

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed:

IMPROVEMENTS PERMIT BY CKB

COMMENTS:

CERTIFICATE OF COMPLETION BY D.R. Hinson, R.S. DATE 7-7-87

EXISTING SYSTEM CHECKED BY: DATE

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold