Copy For Customer

Copy For Owners

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Henry Dyches DATE 10/11/07 PERMIT NO.

PHONE: Business Home

LOCATION 1109 TR 1190 (Sundown) on left ~.1 mile after pavement ends.

SUBDIVISION NAME S. R. No.

LOT NO. SECTION OR BLOCK NO.

House ( ) Mobile Home ( ) Business ( ) Other


No. Bedrooms 3 No. Bathrooms 2 1/2

Garbage Disposal Unit	Yes (✓)	No ( )
Auto. Dishwasher	Yes (✓)	No ( )
Auto. Wash. Machine	Yes (✓)	No ( )
Site Suitable	Yes (✓)	No ( )

Lot Area ~20000 ft²

Character & Porosity of Soil Clay
Percolation Rate .35
Topography 2-15%
Depth to Water Table 3'+
Rock or other impervious formations none observed

_____ Basement with Plumbing _____ Basement without Plumbing ✓ No Basement



Plot of System N.T.S.

Size of Tank Existing (1250) Gals.

Nitrification Field:
No. of Lines 3
Sq. Ft. _____ Linear Ft. 180'
Depth of Stone in Lines at 16" T&J

Water Supply: Individual (✓) Panels
Public ( )

Installed by Owner

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed:

The proposed / existing GARAGE ADDITION addition does not appear to impact the existing septic system.
**NOTE:

Wesley Sparks R.S.
Date: 10/21/09
ICHD-Environmental Health Division

IMPROVEMENTS PERMIT BY DPU

COMMENTS: Existing tank used. ~5' off foundation

CERTIFICATE OF COMPLETION BY Andrew C Queen DATE 10/14/07

EXISTING SYSTEM CHECKED BY: _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Improvement Permit