4646-27-7725

David Currier
Owner of:
LAKE NORMAN SEWER AND SEPTIC
3405 Denver Drive,
Denver, NC 28037
(704)-483-5125

License Number: 995940

LAKE NORMAN SEWER & SEPTIC®

Customer Number: #03543

Date of Inspection: MARCH 23RD, 2015

☒Initial ☐6 Months

Subsurface Wastewater Inspection Form

Lot Number: #8

Name & Address of Owner:
JAY & ROSEANN HARRILL
175 CORONA CIRCLE
MOORESVILLE NC 28117

SEPTIC TANK:

Size of Septic Tank: 1,500 Gallons.
Size of Pump Tank: 1,000 Gallons.

☒ Risers Readily Accessible
☒ No Signs of Infiltration
☒ Structurally Sound
☒ Filter(s) Cleaned
☒Surface Water Diverted at System
Scum Level: 0"
Sludge Level: 4"
Scum plus Sludge level: 4"
Liquid Depth: 44" (> 30%)

TANK NEEDS PUMPING: ☐YES ☒ NO
Field Location: ☒Onsite ☐ Offsite

PUMP:

Pump Model: MYERS
Pump HP: .5 HP
Pump Voltages: 240

☒High water alarm operating properly
☒Pipework in good condition
☒Control Panel in Good Condition
Location of Control Panel
☐Wall ☒Post 18" inches High
☒Control floats operating properly
☒Effluent free & clear of solids

Head Settings:
☐2' ☐ 3' ☒other _____

TYPE OF SYSTEM:

☒Type IV
(50% reduction)
☐Type III
(25% reduction)
☐LPP OR ☐DRIP
☐Gravity Septic
☐Pump to Gravity

REDUCTION TYPE:

☐Polystyrene
☐Chamber
☒Other (TJ PANEL)

Notes and/or Corrective Action Needed:

At the time of the inspection the septic system was functioning as intended. We will be back out in 6 months to perform another inspection. If you have any questions please give our office a call.

INSPECTOR SIGNATURE: David D Currier

DISTRIBUTION TYPE:

☒Manifold
☐D-Box
☐Serial
Lines 3 X Ft long
TOTAL= 330 Ft Line.
☒Varies

☒No effluent surfacing
☒ Traffic Protected
☒Surface Water Diverted
☒Line Cover Maintained
☒Distribution Set
☒ Repair Area Reserved

LOW PRESSURE SYSTEM:

☒Turn-ups, Clean-Outs, Valves Located/ Protected
☒Laterals Free of Excess solids
☒Laterals Flushed
☒Pressure Head Setting for Each Line