4646304739

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Ralph Walker DATE 12-11-14 PERMIT NO. 3328

PHONE: Business _____ Home _____

LOCATION Hwy 70 on Service Road East Turn Left on First Left Stay Left Lot is on Left S. R. No. _____

SUBDIVISION NAME Catawba Cove LOT NO. 10 SECTION OR BLOCK NO. _____


House (X) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 1

Garbage Disposal Unit	Yes	( )	No	(X)
Auto. Dishwasher	Yes	( )	No	(X)
Auto. Wash. Machine	Yes	(X)	No	( )
Site Suitable	Yes	(X)	No	( )

Lot Area 21,100 Sqft

Character & Porosity of Soil Sandy Clay Loam Moderate
Percolation Rate 20 min/in
Topography > 2 % Slope
Depth to Water Table 16" +
Rock or other impervious formations None



Plot of System

Size of Tank 1000 Gals.
Nitrification Field:
No. of Lines 3
Sq. Ft. 625 Linear Ft. 250
Depth of Stone in Lines 10"
Water Supply: Individual (X)
Public ( )

Installed by Master Septic Tank Service

IMPROVEMENTS PERMIT BY Gene Houston

COMMENTS: _____

CERTIFICATE OF COMPLETION BY Gene Houston DATE 12-15-14

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Robert Wheeler DATE 9-16-14 PERMIT NO. 256

PHONE: Business _____ Home _____

LOCATION [redacted] US 21 S Take on Sewage Plant Turn Left [redacted] on Port Road Stay Left Lot 10 on Left S. R. No. _____

SUBDIVISION NAME Pebble Cove LOT NO. 10 SECTION OR BLOCK NO. C


House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 1

Garbage Disposal Unit	Yes	( )	No	(✓)
Auto. Dishwasher	Yes	( )	No	(✓)
Auto. Wash. Machine	Yes	(✓)	No	( )
Site Suitable	Yes	(✓)	No	( )

Lot Area 21,000 sq ft

Character & Porosity of Soil Sandy Clay loam very friable
Percolation Rate 30 min/in
Topography 2 to 6%
Depth to Water Table 10'
Rock or other impervious formations None



Plot of System

Size of Tank 1000 Gals.
Nitrification Field:
No. of Lines 3
Sq. Ft. 625 Linear Ft. 250
Depth of Stone in Lines 12"
Water Supply: Individual (✓)
Public ( )

Installed by _____

IMPROVEMENTS PERMIT BY John Hewitt

COMMENTS: Set home 100' back from Road

CERTIFICATE OF COMPLETION BY _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold