I-SITE WASTEWATER SECTION

COUNTY: _____

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

WNER: Jay White APPLICANT: _____

DDRESS: _____ APPLICATION DATE: _____ DATE EVALUATED: 5/7/01

OPOSED FACILITY: 480 - 3 BR PROPOSED DESIGN FLOW (.1949): 480 PROPERTY SIZE: .7 Ac

CATION OF SITE: Williamson ST TR Alcove TR Catalina off Rest Bapt Church PROPERTY RECORDED: _____

ATER SUPPLY: ☒ Private ☐ Public ☐ Well ☐ Spring ☐ Other _____

ALUATION METHOD: ☒ Auger Boring ☐ Pit ☐ Cut

PE OF WASTEWATER: ☒ Sewage ☐ Industrial Process ☐ Mixed

.1940 LAND-SCAPE POSITION/ SLOPE %	HORI-ZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) .1941 STRUCTURE/ TEXTURE	SOIL MORPHOLOGY (.1941) .1941 CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	.1956 SAPRO CLASS	.1944 RESTR HORIZ	PROFILE CLASS & LTAR
2% NIRR NCCL	0 - 8	sbk / l ~ cl	FR SS SP					
	9 - 26	wk / cl	SEVP FI SS SP					.25
	27 - 33	wk sbk / c / SAP	SEVP FI SS SP					
	34 - 49	SG / cl SAP	SEVP FR SS SP	PS	S	PS	No	.35

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
ailable Space (.1945)		
tem Type(s)		
LTAR		

OTHER FACTORS (.1946): _____

SITE CLASSIFICATION (.1948): _____

EVALUATED BY: _____

OTHER(S) PRESENT: _____