Proposed Future Repair

IREDELL COUNTY HEALTH DEPARTMENT

Statesville Office (704) 878-5305 Mooresville Office (704) 660-3625 PERMIT # 204092

IMPROVEMENT PERMIT / AUTHORIZATION TO CONSTRUCT / OPERATION PERMIT / EXISTING SYSTEM

PIN # 4646332100

APPLICANT: Charles & Amy Hannan APPLICANT ADDRESS: 3 Sandra Circle Douglas, MA 01516

SITE ADDRESS: 389 Ponderosa Circle Mooresville, NC PHONE: ALT. PHONE: 508 797 7190

SITE DIRECTIONS: US21 South Cross over I-77 turns into Williamson Rd TL Ponderosa Circle bear right at fork on right

SUBDIVISION: Bonanza SECTION: LOT # 84 LOT AREA: .486Ac DESIGN FLOW: 360gpd L.T.A.R.: .3

Existing / Future Repair

Septic Tank	1000 (gal)	STB	Date	☐ New System	☒ Repair	☐ Expansion	System Type: I II III IV V VI	☒ Residence	No. Bedrooms 3
Pump Tank	1000 (gal)	PT	Date	System Description:	Gravity -25% Reduction			☐ Business	No. Persons 6
Pump Make		Model	Serial #	Repair System Description:	☒ PPBPS			☐ Other	No. Employees
# Nitrification Fields	1	# Lines	5	Linear Ft:	206'	Maintenance Agreement Required:	☐ YES	☒ NO	☐ Slab ☒ Crawl Space
Trench Width	24" min	Max. Trench Bottom Depth	36"	Gravel Depth	N/A	☒ GRAVITY	☒ PRESSURE		☐ Basement w/ plumbing ☐ Basement w/o plumbing

Water Supply: ☒ Private ☐ Public ☐ Community

Comments / Conditions: ☒ Repair Changed to PPBPS due to concrete pad in current repair area.

INITIAL SITE SKETCH

See approved/attached plan by S Ashley Rollans LSS. for Revised Repair System.

AS BUILT SKETCH

Permit can be suspended or revoked if any false information is supplied toward securing the permit / any unauthorized changes are made to the site / any unauthorized changes are made in the installation of the system. **CONTACT A LOCATOR SERVICE PRIOR TO ANY EXCAVATION**

☐ **IMPROVEMENT PERMIT** *with plat valid without expiration.* ☐ **IMPROVEMENT PERMIT** *with site plan valid for 60 mos.* ☐ **AUTHORIZATION TO CONSTRUCT** *valid for period equal to IMPROVEMENT PERMIT--not to exceed 60 mo.*

Owner / Applicant Signature: Date: 7/11/14 Installed by:

IMPROVEMENT PERMIT by: Maria Dalton RS Date: 7/2/14 OPERATION PERMIT by: Date:

AUTHORIZATION TO CONSTRUCT by: Maria Dalton RS Date: 7/2/14 Existing System Inspected by: Maria Dalton RS Date: 7/2/14

Health Dept. Copy - WHITE Applicant (Final Approval) - YELLOW Applicant (Conditional Approval) - PINK