4646-33-5560

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Marvin E. Brotherton DATE 1-16-87 PERMIT NO. 35

PHONE: Business _____ Home _____

LOCATION 1109 JR on Ponderosa circle 1 mile on left

S. R. No. _____

SUBDIVISION NAME Bonanza LOT NO. 57 SECTION OR BLOCK NO. _____


House ( ) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms _____ No. Bathrooms _____

Garbage Disposal Unit	Yes ( )	No (✓)	Character & Porosity of Soil	clay	
Auto. Dishwasher	Yes (✓)	No ( )	Percolation Rate	.4	
Auto. Wash. Machine	Yes (✓)	No ( )	Topography	2 to 6 %	
Site Suitable	Yes (✓)	No ( )	Depth to Water Table	10' +	
			Rock or other impervious formations	none obs	

Lot Area _____

_____ ~~Basement with Plumbing~~ _____ Basement without Plumbing _____ No Basement



Size of Tank 1250 Gals.

Nitrification Field:
No. of Lines 3
Sq. Ft. 400 Linear Ft. 300
Depth of Stone in Lines 3

Water Supply: Individual (✓)
Public ( )

Installed by Ray Beam

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: _____

IMPROVEMENTS PERMIT BY J. C. Moore

COMMENTS: _____

CERTIFICATE OF COMPLETION BY Charles K. Bennett DATE 1-16-87

EXISTING SYSTEM CHECKED BY: _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold