4646354959

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Jimmy Sides DATE 8-10-71 PERMIT NO. 209

PHONE: Business _____ Home 892-1066

LOCATION 107 TR2 on 1190 TL on 1210

S. R. No. _____

SUBDIVISION NAME Moreland Estates LOT NO. 10 SECTION OR BLOCK NO. _____

Site Address: 138 Elysian Dr., MVL 28117

House ( ) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 3

Garbage Disposal Unit	Yes	( )	No	(✓)
Auto. Dishwasher	Yes	(✓)	No	( )
Auto. Wash. Machine	Yes	(✓)	No	( )
Site Suitable	Yes	(✓)	No	( )

Character & Porosity of Soil Clay loam (Porosity Fair)

Percolation Rate Soil tubings


Topography 2% Slope

Depth to Water Table [redacted] 6' to 8' to lake level

Rock or other impervious formations _____

Lot Area ½ acre

Lake / Ditch 10'X67' 4 lines



Plot of System

Size of Tank 1000 Gals.

Nitrification Field:
No. of Lines 4
Sq. Ft. 625 Linear Ft. 250
Depth of Stone in Lines 10"

Water Supply: Individual ( )
Public ( )

Installed by F. J. Ervin

IMPROVEMENTS PERMIT BY John Houston

COMMENTS: _____

CERTIFICATE OF COMPLETION BY R. C. Moore DATE 8-10-71

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold