IREDELL COUNTY HEALTH DEPARTMENT 46463644484

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Marcus H. Ballard DATE 5-19-08 PERMIT NO. 58

PHONE: Business _____ Home 663-5361


LOCATION 1109 TR on 1190 TL on 1209 1/4 mi on left S. R. No. _____

SUBDIVISION NAME Morelawn Estates LOT NO. 65 SECTION OR BLOCK NO. _____

House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 2
Garbage Disposal Unit Yes (✓) No ( )
Auto. Dishwasher Yes (✓) No ( )
Auto. Wash. Machine Yes (✓) No ( )
Site Suitable Yes (✓) No ( )
Lot Area 1/2 acre +

Character & Porosity of Soil clay loam porosity fair
Percolation Rate Soil borings
Topography 3% slope
Depth to Water Table 6+ft
Rock or other impervious formations none



Size of Tank 1500 Gals.
Nitrification Field:
No. of Lines 2
Sq. Ft. 625 Linear Ft. 250
Depth of Stone in Lines 10"
Water Supply: Individual (✓)
Public ( )

Installed by Harrison Robeson

IMPROVEMENTS PERMIT BY John Houston

COMMENTS: _____

CERTIFICATE OF COMPLETION BY [signature] DATE 5-19-08

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold