IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Moncrief H. Ballard DATE 5-19-78 PERMIT NO. 88

PHONE: Business _____ Home 663-5861

LOCATION 1109 TR on 1190 TL on 1209 1/8 mi on left

SUBDIVISION NAME Moreland Estates LOT NO. 65 SECTION OR BLOCK NO. _____ S. R. No. _____


House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit	Yes (✓)	No ( )
Auto. Dishwasher	Yes (✓)	No ( )
Auto. Wash. Machine	Yes (✓)	No ( )
Site Suitable	Yes (✓)	No ( )

Lot Area 1/2 acre +

Character & Porosity of Soil Clay loam Porosity Fair
Percolation Rate Soil borings
Topography 3-5% slope
Depth to Water Table 4 ft
Rock or other impervious formations None



Size of Tank 1500 Gals.
Nitrification Field:
No. of Lines 2
Sq. Ft. 625 Linear Ft. 250
Depth of Stone in Lines 10"
Water Supply: Individual (✓)
Public ( )

Installed by Harrison
Robeson

IMPROVEMENTS PERMIT BY John Haulston

COMMENTS: _____

CERTIFICATE OF COMPLETION BY R. C. Moore DATE 5-19-78

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold