4646364905

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR R. A. Smith DATE 11-20-79 PERMIT NO. 399

PHONE: Business _____ Home _____

LOCATION 150 w TL on 1109 TR on 1190

_____ S. R. No. _____


SUBDIVISION NAME Idlewood Shores LOT NO. 99 SECTION OR BLOCK NO. _____

House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 4 No. Bathrooms 2

Garbage Disposal Unit	Yes ( )	No (✓)	Character & Porosity of Soil	Clay Loam	
Auto. Dishwasher	Yes (✓)	No ( )	Percolation Rate	30 min/in	
Auto. Wash. Machine	Yes (✓)	No ( )	Topography	Fairly Level	
Site Suitable	Yes (✓)	No ( )	Depth to Water Table	sunk.	
			Rock or other impervious formations	some scattered rock	

Lot Area 20,000 ft² +



Plot of System

Size of Tank 1250 Gals.

Nitrification Field:
No. of Lines 3
Sq. Ft. 1000 Linear Ft. 333
Depth of Stone in Lines 10"

Water Supply: Individual (✓)
Public ( )

Installed by J. R. Burles

IMPROVEMENTS PERMIT BY DRK

COMMENTS: _____

CERTIFICATE OF COMPLETION BY David R. Hinson DATE 11-30-79

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold