4646369625

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR O.S. McNeely - Barlow House DATE 1-23-76 PERMIT NO. 18

PHONE: Business _____ Home _____

LOCATION 409 TR on 1190 TR on 1209

S. R. No. _____

SUBDIVISION NAME Meadowland Estates LOT NO. _____ SECTION OR BLOCK NO. _____


House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 1½

Garbage Disposal Unit Yes ( ) No (✓)
Auto. Dishwasher Yes (✓) No ( )
Auto. Wash. Machine Yes (✓) No ( )
Site Suitable Yes (✓) No ( )

Character & Porosity of Soil Clay loam Porous Fair
Percolation Rate Not Taken
Topography 2% Slope
Depth to Water Table 10 ft
Rock or other impervious formations None

Lot Area ½ acre



Plot of System

Size of Tank 1000 Gals.
Nitrification Field:
No. of Lines 2
Sq. Ft. 625 Linear Ft. 250
Depth of Stone in Lines 10
Water Supply: Individual (✓)
Public ( )

Installed by _____

IMPROVEMENTS PERMIT BY John Houston

COMMENTS: _____

CERTIFICATE OF COMPLETION BY _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold