IREDELL COUNTY HEALTH DEPARTMENT

4646372221

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130, Article 13C)

OWNER OR CONTRACTOR C.W. Brewer Jr. DATE 3/23/84 PERMIT NO. 81

PHONE: Business _____ Home _____

LOCATION 150W TR1109 TR1190 About 1/3 mile on left before Mocksford Estates

SUBDIVISION NAME Dellwood Harbor LOT NO. 119 SECTION OR BLOCK NO. _____ S. R. No. _____


House (X) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit	Yes ( )	No (X)
Auto. Dishwasher	Yes (X)	No ( )
Auto. Wash. Machine	Yes (X)	No ( )
Site Suitable	Yes (X)	No ( )

Lot Area 200' x 206'

Character & Porosity of Soil Clay loam
Percolation Rate 0.5 in 1 ft 2 days
Topography B-10%
Depth to Water Table 4
Rock or other impervious formations None Observed



Size of Tank 1000 Gals.
Nitrification Field:
No. of Lines 2
Sq. Ft. 720 Linear Ft. 240
Depth of Stone in Lines 12"
Water Supply: Individual (X)
Public ( )

Installed by Richard Abernathy

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: _____

IMPROVEMENTS PERMIT BY FHC

COMMENTS: _____

CERTIFICATE OF COMPLETION BY Fred Clemmer DATE 3/23/84

EXISTING SYSTEM CHECKED BY: _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.
Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold