IREDELL COUNTY HEALTH DEPARTMENT 4646372757

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Garland Hudgens DATE 5-13-80 PERMIT NO. 126

PHONE: Business _____ Home _____

LOCATION 150 W TR 1109 TR 1190 ~ ½ Mile on left

S. R. No. _____

SUBDIVISION NAME Idlewood Harbor LOT NO. 114 SECTION OR BLOCK NO. _____

House (X) Mobile Home ( ) Business ( ) Other _____


No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit	Yes	( )	No	(X)
Auto. Dishwasher	Yes	(X)	No	( )
Auto. Wash. Machine	Yes	(X)	No	( )
Site Suitable	Yes	(X)	No	( )

Lot Area 20,000 ft²

Character & Porosity of Soil Clay loam
Percolation Rate 30 min
Topography 2-4%
Depth to Water Table unknown
Rock or other impervious formations None observed

_____ Basement with Plumbing _____ Basement without Plumbing _____ No Basement



Plot of System

Size of Tank 1000 Gals.
Nitrification Field:
No. of Lines 2
Sq. Ft. 750 Linear Ft. 250
Depth of Stone in Lines 10"
Water Supply: Individual (X)
Public ( )

Installed by F. J. Ervin

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: _____

IMPROVEMENTS PERMIT BY Fred Clemmer

COMMENTS: _____

CERTIFICATE OF COMPLETION BY Fred Clemmer DATE 5-13-80

EXISTING SYSTEM CHECKED BY: _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.
Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold