4046374336

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Brewer Realty DATE 5-4-79 PERMIT NO. 127

PHONE: Business _____ Home _____

LOCATION 150 w IL on 109 TR on 1190

S. R. No. _____

SUBDIVISION NAME Idlewood Harbor LOT NO. 103 SECTION OR BLOCK NO. _____


House ( ) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit	Yes	(✓)	No	( )
Auto. Dishwasher	Yes	(✓)	No	( )
Auto. Wash. Machine	Yes	(✓)	No	( )
Site Suitable	Yes	(✓)	No	( )

Lot Area Last

Character & Porosity of Soil Clay loam
Percolation Rate 60 min/in
Topography 10 to 20% slope
Depth to Water Table 20+ ft
Rock or other impervious formations None



Plot of System

Size of Tank 1500 Gals.
Nitrification Field:
No. of Lines 3
Sq. Ft. 750 Linear Ft. 250'
Depth of Stone in Lines 20"
Water Supply: Individual (✓)
Public ( )

Installed by Wayne Osborn

IMPROVEMENTS PERMIT BY _____

COMMENTS: _____

CERTIFICATE OF COMPLETION BY John Thurston DATE 5-4-79

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold