IREDELL COUNTY HEALTH DEPARTMENT

APPENDIX H

SITE EVALUATION

(Ground Absorption Sewage Disposal)

OWNER: C. W. Brewer Realty

ADDRESS:

COUNTY: Iredell

LOCATION OF SITE: 150W TL 1109 TR 1190 TL 1290 TR 1291 off Redwood Rd

DATE REQUESTED: 12-5-80

PLAT NO.: Idlewood Estates #105

LOT SIZE:

FACTORS	AREA 1	AREA 2	AREA 3	AREA 4
1. SLOPE (%)	(S) PS U 2%	S PS U	S PS U	S PS U
2. SOIL TEXTURE (12-36 in.) (Sandy, loamy, clayey, Note 2:1 clay)	S (PS) U clay	S PS U	S PS U	S PS U
3. SOIL STRUCTURE (12-36 in.) (Clayey soils)	S (PS) U Subangular blocky	S PS U	S PS U	S PS U
4. SOIL DEPTH (In.)	(S) PS U 48"	S PS U	S PS U	S PS U
5. RESTRICTIVE HORIZONS (In.) (Impervious Strata, rock)	(S) PS U None observed	S PS U	S PS U	S PS U
6. SOIL DRAINAGE/GROUNDWATER (External & Internal)	(S) PS U No Mottles	S PS U	S PS U	S PS U
7. SOIL PERMEABILITY (Percolation Rate)	S (PS) U Slow	S PS U	S PS U	S PS U
8. OTHER (Specify)	S PS U	S PS U	S PS U	S PS U
9. SITE CLASSIFICATION*	PS			
SOIL SERIES	Cecil			

S - Suitable PS - Provisionally Suitable U - Unsuitable

See Diagram on Back (Include: Soil areas, property lines, roads, streams, gullies, wet areas, fill areas, wells, water bodies, slope patterns, etc.)

Recommendations/Comments: Keep system away from low area

Described By: Fred Brewer

Title: S-I

Date: 12-4-80

HS Form 2601 (2/77)
Supersedes Previous Edition