4646-37-4746

12938

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION

(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Jerry Bennette DATE 8/13/91 PERMIT NO. 2-T 10A-107

PHONE: Business _____ Home _____

LOCATION 150W TL 1109, TR 1190 (Sundown Rd) TL 1290 (Brockway) TR 1291 Moreland Dr. S. R. No. 1291

SUBDIVISION NAME Idlewood Harbor LOT NO. 107 SECTION OR BLOCK NO. _____


House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit	Yes ( )	No (✓)	Character & Porosity of Soil	PS clay	
Auto. Dishwasher	Yes (✓)	No ( )	Percolation Rate	.4	
Auto. Wash. Machine	Yes (✓)	No ( )	Topography	20%	
Site Suitable	Yes (✓)	No ( )	Depth to Water Table	>48"	
			Rock or other impervious formations	some scattered rock	

Lot Area 100' x 200'

_____ Basement with Plumbing _____ Basement without Plumbing _____ No Basement



Plot of System

Size of Tank 1000 Gals.

Nitrification Field:

No. of Lines 4

Sq. Ft. Plee Linear Ft. 320

Depth of Stone in Lines 12"

Water Supply: Individual (✓)

Public ( )

Installed by Larry Beam

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: _____

IMPROVEMENTS PERMIT BY _____

COMMENTS: _____

CERTIFICATE OF COMPLETION BY Wesley Sparks RS. DATE 8/13/91

EXISTING SYSTEM CHECKED BY: _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold

MOORE RETAINING DR.