DEPARTMENT OF ENVIRONMENT,
HEALTH, & NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH

SHEET ____ OF ____
PROPERTY I.D.#: ____
PROPERTY RECORDED: ____
COUNTY: ____

SOIL/SITE EVALUATION
FOR
ON-SITE WASTEWATER SYSTEM

APPLICANT: C W Brewer OWNER: AGENT: PHONE: ____
ADDRESS: ____ APPLICATION DATE: ____ DATE EVALUATED: 3/7/95
PROPOSED FACILITY: 3 Bedroom SFR
PROPERTY SIZE: ____
LOCATION OF SITE: Lot 25 Harwood Estates
WATER SUPPLY: On-Site Well ✓ Comm. Well ___ Public ___ Other ____ EVAL. METHOD: Auger Boring ✓ Pit ___ Cut ___

PROFILE #	.1940 LANDSCP POS. (%)	HORIZON DEPTH (IN.)	.1941 STRUCTURE/TEXTURE	.1941 MINERALOGY/ CONSISTENCE	.1942 WETNESS COND.	.1944 RESTRICT HORIZONS	.1948 CLASS OF HORIZ	1943/ 1956 SAPRLT CLASS.	HORIZON LTAR
1		0-3	sab cl						.3
		3-12	sab c						
		12-25	wk sab cl	many					
		25-48	wk sab cl	many					
			4 parts of water						
2									
3									
4									
5									

AVAILABLE SPACE (.1945) ____ SITE CLASSIFICATION (.1948): ____ SITE LONG-TERM ACCEPTANCE RATE: .3

EVALUATED BY: ____ OTHER(S) PRESENT: ____

COMMENTS: House staked on site smaller than what is shown on Sub plan. Area 45' long x 35' across. No problem areas noted.