4646377306

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION

(Ground Absorption Sewage Disposal System - G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Phil McGuire DATE 6-26-79 PERMIT NO. 219

PHONE: Business _____ Home _____

LOCATION 150W TL on 1109 TR on 1190

S. R. No. _____

SUBDIVISION NAME Idlewood Harbor LOT NO. 91 SECTION OR BLOCK NO. _____

House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit Yes (✓) No ( )

Auto. Dishwasher Yes (✓) No ( )

Auto. Wash. Machine Yes (✓) No ( )

Site Suitable Yes (✓) No ( )

Lot Area 1/2 Ac +


Character & Porosity of Soil clay loam

Percolation Rate 60 mpi

Topography 2%

Depth to Water Table sink

Rock or other impervious formations none obs



Plot of System

Size of Tank 1250 Gals.

Nitrification Field:

No. of Lines 2

Sq. Ft. 750 Linear Ft. 250

Depth of Stone in Lines 18"+

Water Supply: Individual (✓)

Public ( )

Installed by FJ Ervin

IMPROVEMENTS PERMIT BY John Houston

COMMENTS: _____

CERTIFICATE OF COMPLETION BY David R. Hinson DATE 6-26-79

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold