4646-37-7406

IREDELL COUNTY HEALTH DEPARTMENT ENTERED

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Brewer Realty DATE 7-27-79 PERMIT NO. 259

PHONE: Business _____ Home _____

LOCATION 150W TL on 1109 TR on 1190

S. R. No. _____

SUBDIVISION NAME Idlewood Harbor LOT NO. 90 SECTION OR BLOCK NO. _____


House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit Yes (✓) No ( )
Auto. Dishwasher Yes (✓) No ( )
Auto. Wash. Machine Yes (✓) No ( )
Site Suitable Yes (✓) No ( )

Lot Area ½AC +

Character & Porosity of Soil clay loam
Percolation Rate _____
Topography 6% slope.
Depth to Water Table _____
Rock or other impervious formations none obs.



Plot of System

Size of Tank 1500 Gals.
Nitrification Field:
No. of Lines 2
Sq. Ft. 750 Linear Ft. 250
Depth of Stone in Lines 10"
Water Supply: Individual (✓)
Public ( )

Installed by Wayne Robison

IMPROVEMENTS PERMIT BY John Houston

COMMENTS: _____

CERTIFICATE OF COMPLETION BY David R. Hinson DATE 7-27-79

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold